

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 2220043

Ordering firm: KOPOS KOLÍN a.s.  
Havlíčkova 432, 280 02 Kolín IV, Czech Republic

Manufacturer/Licence holder: KOPOS KOLÍN a.s.  
Havlíčkova 432, 280 02 Kolín IV, Czech Republic

Name of product: Wiring floor boxes KOPOBOX MINI and accessories

Trade name:

Type of product: KOPOBOX MINI B  
KOPOBOX MINI L  
KOPOBOX MINI P

Rating: -5 °C to +60 °C, 500 V, IP30 (closed lid), IP20 (opened lid and modular devices with IP20)

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESC Mark” certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 221568-01/01 of: 25.11.2022

A sample of the product was tested and found to be in conformity with:

ČSN EN IEC 60670-1 ed. 2:21+A11:21, ČSN EN 60670-1:05+Z1:10+A1:13, ČSN EN 60670-23:09, ČSN EN 60695-11-5 ed. 2:17

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. 221041-01 of: 12.05.2022
- the Agreement on the use of the ESC Mark No. 221568 concluded between the ordering firm and the Electrotechnical Testing Institute

Other data:

07.12.2022

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



\* C E R / 2 2 2 0 0 4 3 \*

221568-01