

EU DECLARATION OF CONFORMITY

No. 1B-EU-49/23-04

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**
 Havlíčkova 432
 280 02 Kolín
 Czech Republic
 IČ: 61672971
 DIČ: CZ61672971

declare under our sole responsibility that

the product/type: **Double-phase injection boxes and accessories no.2**

manufacturer: **KOPOS KOLÍN a.s. Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: It serves as a conduit boxes into hollow walls eg. of drywall or wood paneling.
 Test with flaming loop: 850 ° C
 The needle burner test was conducted in accordance with ČSN EN 60695-11-5.
 Minimum and maximum temperatures during installation are: -5 ° C to + 60 ° C.
 The IP30 protection a box fitted with an appropriate lid or a device with a higher or equal IP30 protection.

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed.2:21 including amendments ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments)	Test Report No. 230611-01/01 of 22.03.2023 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	X
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments)	Test Report No. 803994-01/01 of 21.1.2019 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	X
			internal protocols	
Regulation 1907/2006 - REACH				Safety data sheets for used materials

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.

Conformity assessment module: **MODUL A: Internal production control**

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogy>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015, ISO 50001:2018 and according to the National program „Safety Enterprise“.


Signed on behalf of KOPOS KOLÍN a.s.

Place of issue: Kolín, Czech Republic

Date of issue: 05.04.2023



Ing. Jana Dejmková
quality director

KOPOS KOLÍN a.s. 
Havlíčkova 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

Enclosure No. 1 to EU Conformity Declaration No. 1B-EU-49/23-04

Double-phase injection boxes and accessories no.2

Type

**KPL 64-40/LD
KP 64-40/LD**

**KPL 64-50/LD
KP 64-50/LD**

**KPL 64-40/2LD
KP 64-40/2LD**

**KPL 64-40/3LD
KP 64-40/3LD**

**KPL 64-40/4LD
KP 64-40/4LD**

**KPL 64-40/5LD
KP 64-40/5LD**

**KOL 86/LD
KO 86/LD**

Accessories

Etrier 50

Fixoplaf

Brackets

Bar

**Screws
3x25
3x35**



KOPOS KOLÍN a.s. ©
Havlíčková 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

