



PAVUS[®]
FIRE TESTING INSTITUTE

PAVUS, a.s., Prosecká 412/74, 190 00 Prague 9 – Prosek, Czech Republic
Product Certification Body No. 3041
accredited according to ČSN EN ISO/IEC 17065
Certificate of Accreditation No. 588/2022 issued by Czech Accreditation Institute,
Public Service Company

issues

according to the scope of the accreditation

C E R T I F I C A T E

No. C-2024/0094

issued for

manufacturer:

KOPOS KOLÍN a.s., Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic,
ID 61672971

place of manufacture:

KOPOS KOLÍN a.s., Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic

for product:

KOPOS cable support systems

Cable runways with circuit integrity maintenance under fire conditions

The certificate declares conformity of the certified product with declared product performance, assessed according to the certification scheme PAVUS-2, 9/2020 (based on the scheme 5 ISO/IEC 17067, based on the testing and the audit QM) and according to requirements in DIN 4102-12:1998, according which the certification has been carried out.

Test results and findings are stated in Certification report No. P-2024/0094 from 2nd May 2024 that is an integral part of this certificate and is handed along with this certificate.

This certificate replaces and cancels the Certificate No. C-2021/0097, dated 24.8.2021, issued by Certification Body No. 3041.

Certificate validity is limited to: 31st May 2027

Prague, 2nd May 2024



Jaroslav Kopečný

Executive of the CB for product certification 3041

Assessed performances of the certified product are stated on the other side of this certificate.

Verze 7


Second page of the Product Certificate No. C-2024/0094

Assessed performance of the certified product

Monitored/declared performance	Determined (requirement)/ classification standard	Required/declared level	Observed/ classification	Conformity Assessment
Circuit integrity maintenance of cable runways under fire conditions	DIN 4102-12	E 30 to E 90	<ul style="list-style-type: none"> - Cable trays MARS - Cable trays JUPITER - Wire cable trays - Cable ladders - Cable clamps - Pipes - Parapets and trunkings - Wiring boxes - Supporting rails, profiles and tightening belts - Accessories <p align="center">E 30 to E 90</p>	Conforms ¹⁾
Reaction to fire	ČSN 73 0810 EN 13501-1	Steel elements: A1 Wiring boxes: E Pipes, parapets and trunkings: E	Steel elements: A1 Wiring boxes: E Pipes, parapets and trunkings: E	Conforms ²⁾
<p>1) Conforms according to the test results in [2 – 57] Clause 2 of the Certification report.</p> <p>2) Conforms according to the test results in [58, 59] Clause 2 of the Certification report.</p>				

The validity of the Certificate No. C-2024/0094 is limited by date and is conditioned on executing of regular audit on proper implementing of factory production control by manufacturer that has to be executed by the Certification Body No. 3041 at least once every 12 months.




Ing. Jaroslav Kopečný
 Executive of the CB for product certification 3041