



69dB



product  
description:

designed for distribution system with voltage 400 V and with maximum current 16 A  
designed for mounting into hollow walls (eg. walls of plasterboard)  
inlet openings made of flexible material  
marked inputs for sealing cables and pipes in the flexible material (4x Ø6-10 mm, 2x Ø10-16 mm, 2x Ø20-25 mm)  
air-tightness even with inserted cable or pipe  
suitable for low energy and passive houses  
prevents airflow through the installation  
mounting screws with plastic foot are fitted with a twin self-tapping thread for quick installation  
instrument screws are tightened below the edge of the box  
extended edge situated for easy overlay installed device  
when mounting, it is not necessary to countersink the plasterboard edge  
possibility to insert screwless terminals  
when using box with the cover V 68HF, the IP protection is IP 30  
suitable for soundproof walls with maximum soundproofing  $R_w = 69\text{dB}$   
for premises with increased need for protection of persons and property

material: PP ( Pb-free, halogen-free)

color: grey (RAL 7035)

self-snuffing: yes, within 30 s

temperature resistance: -5 - +60 °C

flaming loop test: 850 °C

fire class for underlying material: A1-F

protection types: IP 30

weight: 25 g

meets the requirements: ČSN EN 60670-1, ČSN EN IEC 60670-1 ed. 2:21

storage: ČSN 64 0090

KPRL 64-60/LD HF\_KA - boxes fitted with screws for mounting into double wall and device screws - package: 84 pcs in carton

accessories: cover V 68HF  
screwless terminal plates TYP015, TYP016, TYP017, TYP018

auxiliary tools: saw-drill VPT 64  
universal carrier VPTU

## recycling codes:



## Warning:

Incorrect electrical installation can cause a fire - we recommend the connection to be carried out exclusively by an authorized person.  
Product damage - if the box is visibly damaged, stop using it.  
Follow the manufacturer's installation instructions according to the installation instructions, videos.  
Make sure the box is properly attached and secured to prevent accidental loosening.  
Installing an unsuitable box can negatively affect the sound and thermal insulation of the room.  
Under normal and foreseeable conditions of use, the installed box does not pose any risks to consumers.