

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 2260021

Ordering firm: KOPOS KOLÍN a.s.
Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic

Manufacturer/Licence holder: KOPOS KOLÍN a.s.
Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic

Production site: KOPOS KOLÍN a.s.
Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic

Name of product: Cable tray to protect a line

Trade name:

Type of product: KOPOKAN 1-TP-KO 01-11, KOPOKAN 2-TP-KO 01-22,
KOPOKAN 3-TP-KO 02-22, KOPOKAN 4-TP-KO 01 20
including accessories

Rating: instalation up to 1000 V, 750 N, IP30

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESČ Mark” certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESČ Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 261370-01/01 of: 30.06.2026

A sample of the product was tested and found to be in conformity with:
ČSN EN 50626-1:2024, TP-KO-01/20

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. 260792-01 of: 08.04.2026
- the Agreement on the use of the ESČ Mark No. 261370 concluded between the ordering firm and the Electrotechnical Testing Institute

Other data:

15.07.2026 Corr. 24.07.2026

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



* C E R / 2 2 6 0 0 2 1 *

261370-01